

MEWTOCOL Communication **User's Manual**

(MEMO)

Table of Contents

1 MEWTOCOL-COM (Computer Link)	1-1
1.1 Overview of MEWTOCOL-COM	1-2
1.2 Single Frames and Multiple Frames	1-6
1.3 List of MEWTOCOL-COM Commands	1-8
1.3.1 [RCS] Read contact area (single point)	1-8
1.3.2 [RCP] Read contact area (plural point)	1-9
1.3.3 [RCC] Read contact area (word units block)	1-10
1.3.4 [WCS] Write contact area (single point)	1-10
1.3.5 [WCP] Write contact area (plural points)	1-11
1.3.6 [WCC] Write contact area (word units block)	1-11
1.3.7 [RD] Read data area	1-12
1.3.8 [WD] Write data area	1-13
1.3.9 [RS] Read set value area	1-15
1.3.10 [WS] Write set value area	1-16
1.3.11 [RK] Read elapsed value area	1-16
1.3.12 [WK] Write elapsed value area	1-17
1.3.13 [MC] Register or Reset contacts monitored	1-18
1.3.14 [MD] Register or Reset data monitored	1-18
1.3.15 [MG] Monitoring start	1-19
1.3.16 [SC] Preset contact area (fill command)	1-20
1.3.17 [SD] Preset data area	1-21
1.3.18 [RT] Read the status of PLC	1-22
1.3.19 [RR] Read system register	1-24
1.3.20 [WR] Write system register	1-24
1.3.21 [RM] Remote control	1-25
1.3.22 [AB] Abort	1-26
2 MEWTOCOL-DAT (Data Transfer)	2-1
2.1 Overview of MEWTOCOL-DAT	2-2
2.2 List of MEWTOCOL-DAT Commands	2-4
2.2.1 [50H] Write data area	2-4
2.2.2 [51H] Read data area	2-5
2.2.3 [52H] Write contact information	2-6
2.2.4 [53H] Read contact information	2-6
3 MEWTOCOL Error Codes	3-1
3.1 Table of Error Codes	3-2

(MEMO)

1 MEWTOCOL-COM (Computer Link)


1.1 Overview of MEWTOCOL-COM	1-2
1.2 Single Frames and Multiple Frames	1-6
1.3 List of MEWTOCOL-COM Commands	1-8
1.3.1 [RCS] Read contact area (single point)	1-8
1.3.2 [RCP] Read contact area (plural point)	1-9
1.3.3 [RCC] Read contact area (word units block)	1-10
1.3.4 [WCS] Write contact area (single point)	1-10
1.3.5 [WCP] Write contact area (plural points)	1-11
1.3.6 [WCC] Write contact area (word units block)	1-11
1.3.7 [RD] Read data area	1-12
1.3.8 [WD] Write data area	1-13
1.3.9 [RS] Read set value area	1-15
1.3.10 [WS] Write set value area	1-16
1.3.11 [RK] Read elapsed value area	1-16
1.3.12 [WK] Write elapsed value area	1-17
1.3.13 [MC] Register or Reset contacts monitored	1-18
1.3.14 [MD] Register or Reset data monitored	1-18
1.3.15 [MG] Monitoring start	1-19
1.3.16 [SC] Preset contact area (fill command)	1-20
1.3.17 [SD] Preset data area	1-21
1.3.18 [RT] Read the status of PLC	1-22
1.3.19 [RR] Read system register	1-24
1.3.20 [WR] Write system register	1-24
1.3.21 [RM] Remote control	1-25
1.3.22 [AB] Abort	1-26

1.1 Overview of MEWTOCOL-COM

1.1 Overview of MEWTOCOL-COM

■ Command and response functions


The computer sends commands (instructions) to the programmable controller, and receives responses in return. This enables the computer and programmable controller to converse with each other, so that various kinds of information can be obtained and provided.



Note

- A user program is required on the computer side in order to carry out a computer link.
- No program is necessary on the programmable controller side.

■ Command and response formats



Control codes

Name	Character	ASCII code	Explanation
Header	% or <	25H or 3CH	Indicates the beginning of a message.
Command	#	23H	Indicates that the data comprises a command message.
Normal response	\$	24H	Indicates that the data comprises a normal response message.
Error response	!	21H	Indicates that the data comprises a response message when an error occurs.
Terminator	C _R	0DH	Indicates the end of a message.

Name	Character	ASCII code	Explanation
Delimiter	&(+ ^C _R)	26H	Indicates a delimiter that splits data into multiple frames.

Destination and source

Two-digit decimal 01 to 32, EE, or FF (ASCII codes)

Command messages contain a unit number for the programmable controller that receives the message.

Response messages contain the unit number of the programmable controller that is sending the response.

If there is no particular value to be specified, "01" should be set.

**Note**

- When "FF" is specified, a global transmission (sent to all units at once) is applied.
When a global transmission is sent, no response to the command message is returned.

BCC (Block Check Code)

Two-digit hexadecimal 00 to FF (ASCII codes)

These are codes (horizontal parity) that are used to detect errors in the transmitted data.

If "***" is entered instead of "BCC", however, messages can be transmitted without the BCC. In this case, the BCC is included with the response.

Error code


Indicates error information. If an error occurs in the command, an error code is set as a two-digit hexadecimal 00 to FF (ASCII codes).

■ BCC (Block Check Code)

- The BCC is a code that carries out an error check using horizontal parity, to improve the reliability of the data being sent.
- The BCC uses an exclusive OR from the header (%) to the final character of the text, and converts the 8-bit data into a 2-character ASCII code.

1.1 Overview of MEWTOCOL-COM

Example




■ How data is notated in commands and responses

Data used in commands and responses can be notated in the three ways described below.

Hexadecimal data

"x16⁰, x16¹, ..." indicate hexadecimal data.


(Example) Register contents in a data area read (RD) response



Decimal data

"x10⁰, x10¹, ..." indicate decimal data.

(Example) Initial word contents in a data area read (RD) command




Decimal – hexadecimal data

In the relay numbers for external input (X), external output (Y), internal relays (R), and link relays (L), the last digit is in hexadecimal notation, while the preceding digits are in decimal notation. (In T/C contact numbers, all of the digits, including the last digit, are in decimal notation.)

In this case, the notation would read as follows: "x16⁰, x10¹, x10²..."

(Example) Specification of command contact of contact area lead (RCS)




Note

- Data is limited to a certain number of characters. For example, the contact number above is specified using four characters, so when the X1F contact area is read, a 0 will be added at the beginning to fill out the number of characters and form a four-character string.

1.2 Single Frames and Multiple Frames

1.2 Single Frames and Multiple Frames

■ Single-frame commands and responses




■ Maximum message length

The maximum message length for a single frame of a command or response (the number of characters from the header to the terminator) is as indicated below. If the maximum message length is exceeded, the message should be split into multiple sections and sent. (responses should be split into several frames and sent)

% (Header) 118 characters


< (Expanded header) 2048 characters

■ Multiple-frame commands and responses




■ Sample communication timing chart


(1) Single-frame command and single-frame response




(2) Multiple-frame command and single-frame response



(3) Single-frame command and multiple-frame response



(4) When multiple-frame command is aborted before being completed



Note

- When a transmission is split into several frames and sent, after one frame has been sent, the next frame cannot be sent until a transmission request message (*1 in the sample communication timing chart) has been received from the partner side.
- If multiple frames are being received, a transmission request message (*2 in the sample communication timing chart) should be sent to the partner side so that the next frame can be received.

1.3 List of MEWTOCOL-COM Commands

1.3 List of MEWTOCOL-COM Commands

■ Table of commands

Command name	Code	Description
Read contact area	RC (RCS) (RCP) (RCC)	Reads the on and off status of contacts. • Specifies only one point. • Specifies multiple contacts. • Specifies a range in word units.
Write contact area	WC (WCS) (WCP) (WCC)	Turns contacts on and off. • Specifies only one point. • Specifies multiple contacts. • Specifies a range in word units.
Read data area	RD	Reads the contents of a data area.
Write data area	WD	Writes data to a data area.
Read timer/counter set value area	RS	Reads the value set for a timer/counter.
Write timer/counter set value area	WS	Writes a timer/counter setting value.
Read timer/counter elapsed value area	RK	Reads the timer/counter elapsed value.
Write timer/counter elapsed value area	WK	Writes the timer/counter elapsed value.
Register or Reset contacts monitored	MC	Registers the contact to be monitored.
Register or Reset data monitored	MD	Registers the data to be monitored.
Monitoring start	MG	Monitors a registered contact or data.
Preset contact area (fill command)	SC	Embeds the area of a specified range in a 16-point on and off pattern.
Preset data area (fill command)	SD	Writes the same contents to the data area of a specified range.
Read system register	RR	Reads the contents of a system register.
Write system register	WR	Specifies the contents of a system register.
Read the status of PLC	RT	Reads the specifications of the programmable controller and error codes if an error occurs.
Remote control	RM	Switches the operation mode of the programmable controller.
Abort	AB	Aborts communication.

1.3.1 [RCS] Read contact area (single point)

This reads the on and off status for only one contact.

1.3 List of MEWTOCOL-COM Commands

Command

% or <	Destination $\times 10^1$ $\times 10^0$	#	R	C	S	Contact code 1 char- acter	Contact No. 4 characters $\times 10^3$ $\times 10^2$ $\times 10^1$ $\times 10^0$ ($\times 10^0$)	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	--	---	---	---	---	-------------------------------------	--	------------------------------------	----------------

Treated as single point

Values () are for TM/CT.

Normal response (Read successful)

% or <	Source $\times 10^1$ $\times 10^0$	\$	R	C	Contact code 1 char- acter	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	----	---	---	-------------------------------------	------------------------------------	----------------

Error response (Read error)

% or <	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 16^1$ $\times 16^0$	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	---	---	------------------------------------	----------------

Contact code

Contact	Notation
External input X	"X"
External output Y	"Y"
Internal relay R	"R"
Link relay L	"L"
Timer T	"T"
Counter C	"C"

Contact data

Contact	Notation
ON	"1"
OFF	"0"

1.3.2 [RCP] Read contact area (plural point)

This reads the on and off status for multiple contacts.

Command

% or <	Destination $\times 10^1$, $\times 10^0$	#	R	C	P	n 1 character $\times 10^0$	Contact code 1 character	Contact No. 4 characters $\times 10^3$ $\times 10^2$ $\times 10^1$ $\times 10^0$ ($\times 10^0$)		
						Treated as multiple points	No. of contacts n = 1 to 8	Values () are for TM/CT.		
									Contact specification (n)	
						Contact code 1 character $\times 10^3$ $\times 10^2$ $\times 10^1$ $\times 10^0$ ($\times 10^0$)	Contact No. 4 characters $\times 10^3$ $\times 10^2$ $\times 10^1$ $\times 10^0$ ($\times 10^0$)	BCC $\times 16^1$, $\times 16^0$	C _R	

Normal response (Read successful)

% or <	Source $\times 10^1$ $\times 10^0$	\$	R	C	Contact data (1) 1 char- acter	Contact data (n) 1 char- acter	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	----	---	---	---	---	------------------------------------	----------------

Error response (Read error)

% or <	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 16^1$ $\times 16^0$	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	---	---	------------------------------------	----------------

Contact code

Contact	Notation
External input X	"X"
External output Y	"Y"
Internal relay R	"R"
Link relay L	"L"
Timer T	"T"
Counter C	"C"

Contact data


Contact	Notation
ON	"1"
OFF	"0"

1.3 List of MEWTOCOL-COM Commands


1.3.3 [RCC] Read contact area (word units block)

This reads the on and off status of the contact in word units.


Command



Normal response (Read successful) The contact information is read as hexadecimal data, in word units.



Error response (Read error)




Contact code

Contact	Notation
External input X	"X"
External output Y	"Y"
Internal relay R	"R"
Link relay L	"L"
Timer T	"T"
Counter C	"C"


1.3.4 [WCS] Write contact area (single point)

This turns only one contact on or off.


Command



Normal response (Write successful)



Error response (Write error)



Contact code


Contact	Notation
External output Y	"Y"
Internal relay R	"R"
Link relay L	"L"

Contact data

Contact	Notation
ON	"1"
OFF	"0"

1.3.5 [WCP] Write contact area (plural points)

This turns multiple contacts on and off.



Normal response (Write successful)

% or <	Source $\times 10^1$ $\times 10^0$	\$	W	C	BCC $\times 10^1$ $\times 10^0$	CR
--------------	---------------------------------------	----	---	---	------------------------------------	----

Error response (Write error)

% or <	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 10^1$ $\times 10^0$	BCC $\times 10^1$ $\times 10^0$	CR
--------------	---------------------------------------	---	---	------------------------------------	----

Contact code

Contact	Notation
External output Y	"Y"
Internal relay R	"R"
Link relay L	"L"

Contact data


Contact	Notation
ON	"1"
OFF	"0"

1.3.6 [WCC] Write contact area (word units block)

This turns a contact on or off in word units.

1.3 List of MEWTOCOL-COM Commands

Command The contact information is read as hexadecimal data, in word units.



Normal response (Write successful)

% or <	Source	\$	W	C	BCC	C _R
$\times 10^1$ $\times 10^0$					$\times 16^1$ $\times 16^0$	

Error response (Write error)

% or <	Source	!	Error code	BCC	C _R
$\times 10^1$ $\times 10^0$			$\times 16^1$ $\times 16^0$	$\times 16^1$ $\times 16^0$	

Contact code

Contact	Notation
External output Y	"Y"
Internal relay R	"R"
Link relay L	"L"

1.3.7 [RD] Read data area

This reads the contents of the data area.

To read the contents of DT, LD, and FL:

Command

% or <	Destination	#	R	D	Contact code 1 char- acter	Starting word No. 5 characters					Ending word No. 5 characters					BCC		C _R
	$\times 10^1 \times 10^0$					$\times 10^4$	$\times 10^3$	$\times 10^2$	$\times 10^1$	$\times 10^0$	$\times 10^4$	$\times 10^3$	$\times 10^2$	$\times 10^1$	$\times 10^0$	$\times 16^1$	$\times 16^0$	

Normal response (Read successful)

% or <	Source	\$	R	D	First register contents 4 characters				Last register contents 4 characters				BCC	C _R	
	$\times 10^1$ $\times 10^0$				$\times 16^1$	$\times 16^0$	$\times 16^3$	$\times 16^2$	$\times 16^1$	$\times 16^0$	$\times 16^3$	$\times 16^2$	$\times 16^1$	$\times 16^0$	
					(lower word)		(higher word)		(lower word)		(higher word)				

Error response (Read error)

% or <	Source	!	Error code	BCC	C _R
$\times 10^1$ $\times 10^0$			$\times 16^1$ $\times 16^0$	$\times 16^1$ $\times 16^0$	

Data code

Data	Notation
Data register DT	"D"
Link data register LD	"L"
File register FL	"F"

1.3 List of MEWTOCOL-COM Commands

To read the contents of an index register:

Command

% or <	Destination $\times 10^1$ $\times 10^0$	#	R	D	Data code 2 characters	0	0	0	0	0	0	0	0	0	BCC $\times 16^1$ $\times 16^0$	C _R
						9 characters										

Normal response (Read successful) (For I0 and I1)

% or <	Source $\times 10^1$ $\times 10^0$	\$	R	D	Register contents 4 characters $\times 16^1$ $\times 16^0$ $\times 16^3$ $\times 16^2$				BCC $\times 16^1$ $\times 16^0$	C _R
					(lower word)		(higher word)			

Normal response (Read successful) (For I0 and I1)

% or <	Source $\times 10^1$ $\times 10^0$	\$	R	D	Register contents (I0) 4 characters $\times 16^1$ $\times 16^0$ $\times 16^3$ $\times 16^2$				Register contents (I1) 4 characters $\times 16^1$ $\times 16^0$ $\times 16^3$ $\times 16^2$				BCC $\times 16^1$ $\times 16^0$	C _R
					(lower word)		(higher word)		(lower word)		(higher word)			

Error response (Read error)

% or <	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 16^1$ $\times 16^0$	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	---	---	------------------------------------	----------------

Data code

Data	Notation
I0	"I" "X"
I1	"I" "Y"
I0, I1	"I" "D"


1.3.8 [WD] Write data area

This writes the contents of the data area.

1.3 List of MEWTOCOL-COM Commands

To write the contents of DT, LD, and FL:

Command The contact information is written as hexadecimal data, in word units.



Normal response (Write successful)

% or <	Source $\times 10^1$ $\times 10^0$	\$	W	D	BCC $\times 16^1$ $\times 16^0$	CR
--------------	---------------------------------------	----	---	---	------------------------------------	----

Error response (Write error)

% or <	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 16^1$ $\times 16^0$	BCC $\times 16^1$ $\times 16^0$	CR
--------------	---------------------------------------	---	---	------------------------------------	----


Data code

Data	Notation
Data register DT	"D"
Link data register LD	"L"
File register FL	"F"


To write to an index register:

Command


Writing to I0 and I1:




Writing to I0 and I1 at the same time (32-bit data):



Normal response (Write successful)



Error response (Write error)



Data code

Data	Notation
I0	"I" "X"
I1	"I" "Y"
I0, I1	"I" "D"

1.3.9 [RS] Read set value area

This reads the value set for a timer/counter.

1.3 List of MEWTOCOL-COM Commands

Command

% or <	Destination $\times 10^1$ $\times 10^0$	#	R	S	Starting timer/counter No. 4 characters $\times 10^3$ $\times 10^2$ $\times 10^1$ $\times 10^0$	Ending timer/counter No. 4 characters $\times 10^3$ $\times 10^2$ $\times 10^1$ $\times 10^0$	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	--	---	---	---	---	---	------------------------------------	----------------

Normal response (Read successful)

% or <	Source $\times 10^1$ $\times 10^0$	\$	R	S	First set value 4 characters $\times 16^1$ $\times 16^0$ $\times 16^3$ $\times 16^2$	Last set value 4 characters $\times 16^1$ $\times 16^0$ $\times 16^3$ $\times 16^2$	BCC $\times 16^1$ $\times 16^0$	C _R
					(lower word) (higher word)	(lower word) (higher word)		

Error response (Read error)

% or <	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 16^1$ $\times 16^0$	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	---	---	------------------------------------	----------------

1.3.10 [WS] Write set value area

This writes the value to be set for a timer/counter.

Command

% or <	Destination $\times 10^1$ $\times 10^0$	#	W	S	Starting timer/counter No. 4 characters $\times 10^3$ $\times 10^2$ $\times 10^1$ $\times 10^0$	Ending timer/counter No. 4 characters $\times 10^3$ $\times 10^2$ $\times 10^1$ $\times 10^0$					

Normal response (Write successful)

% or <	Source $\times 10^1$ $\times 10^0$	\$	W	S	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	----	---	---	------------------------------------	----------------

Error response (Write error)

% or <	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 16^1$ $\times 16^0$	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	---	---	------------------------------------	----------------

1.3.11 [RK] Read elapsed value area

1.3 List of MEWTOCOL-COM Commands

This reads the elapsed value for a timer/counter.

Command

% or <	Destination $\times 10^1$ $\times 10^0$	#	R	K	Starting timer/counter No. 4 characters $\times 10^3$ $\times 10^2$ $\times 10^1$ $\times 10^0$	Ending timer/counter No. 4 characters $\times 10^3$ $\times 10^2$ $\times 10^1$ $\times 10^0$	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	--	---	---	---	---	---	------------------------------------	----------------

Normal response (Read successful)

% or <	Source $\times 10^1$ $\times 10^0$	\$	R	K	First elapsed value 4 characters $\times 16^1$ $\times 16^0$ $\times 16^3$ $\times 16^2$	Last elapsed value 4 characters $\times 16^1$ $\times 16^0$ $\times 16^3$ $\times 16^2$	BCC $\times 16^1$ $\times 16^0$	C _R
					(lower word) (higher word)	(lower word) (higher word)		

Error response (Read error)

% or <	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 16^1$ $\times 16^0$	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	---	---	------------------------------------	----------------

1.3.12 [WK] Write elapsed value area

This writes the elapsed value for a timer/counter.

Command

% or <	Destination $\times 10^1$ $\times 10^0$	#	W	K	Starting timer/counter No. 4 characters $\times 10^3$ $\times 10^2$ $\times 10^1$ $\times 10^0$	Ending timer/counter No. 4 characters $\times 10^3$ $\times 10^2$ $\times 10^1$ $\times 10^0$				
							First writing data 4 characters $\times 16^1$ $\times 16^0$ $\times 16^3$ $\times 16^2$	Last writing data 4 characters $\times 16^1$ $\times 16^0$ $\times 16^3$ $\times 16^2$	BCC $\times 16^1$ $\times 16^0$	C _R
							(lower word) (higher word)		(lower word) (higher word)	

Normal response (Write successful)

% or <	Source $\times 10^1$ $\times 10^0$	\$	W	K	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	----	---	---	------------------------------------	----------------


Error response (Write error)

% or <	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 16^1$ $\times 16^0$	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	---	---	------------------------------------	----------------


1.3 List of MEWTOCOL-COM Commands

1.3.13 [MC] Register or Reset contacts monitored


This registers a contact to be monitored. Up to 80 points can be registered for one unit.




Register reset



Normal response (Registration successful)



Error response (Registration error)




Contact code

Contact	Notation
External input X	"X"
External output Y	"Y"
Internal relay R	"R"
Link relay L	"L"
Timer T	"T"
Counter C	"C"


1.3.14 [MD] Register or Reset data monitored

This registers data to be monitored. Up to 16 points can be registered for one unit.


1.3 List of MEWTOCOL-COM Commands




Register reset



Normal response (Registration successful)



Error response (Registration error)



Data code

Data	Data code
Data register DT	D
Link data register LD	L
File register FL	F
Timer/counter set value area SV	S
Timer/counter elapsed value area EV	K
Index register I0	IX
Index register I1	IY
External input WX	WX
External output WY	WY
Internal relay WR	WR
Link relay WL	WL

2-character data code

Note

- If the data code is IX or IY, "0" should be specified for the four characters of the word number.
- Dummy registrations ("**") are not possible when registering data to be monitored.

1.3.15 [MG] Monitoring start


This monitors a contact or data that has been registered.

1.3 List of MEWTOCOL-COM Commands

Command

% or <	Destination $\times 10^1$ $\times 10^0$	#	M	G	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	--	---	---	---	------------------------------------	----------------

Normal response (Monitoring successful)



*1 The base counter returns "A" if scanning took place ten times or more on the PLC side since the previous response.

Error response (Monitoring error)

% or <	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 16^1$ $\times 16^0$	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	---	---	------------------------------------	----------------


- Contact data is entered in the order registered, starting from bit 0 of the contact data (1).
- Data is entered in the order registered, starting from the data (1).

1.3.16 [SC] Preset contact area (fill command)

This embeds the areas of the specified range for 16 on and off points.

1.3 List of MEWTOCOL-COM Commands

Command



Normal response (Preset successful)

% or <	Source $\times 10^1$ $\times 10^0$	\$	S	C	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	----	---	---	------------------------------------	----------------

Contact code

Contact	Notation
External output Y	"Y"
Internal relay R	"R"
Link relay L	"L"


Error response (Preset error)

% or <	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 16^1$ $\times 16^0$	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	---	---	------------------------------------	----------------

1.3.17 [SD] Preset data area

This writes the same contents to the data area of the specified range.

Command



Normal response (Preset successful)

% or <	Source $\times 10^1$ $\times 10^0$	\$	S	D	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	----	---	---	------------------------------------	----------------

Data code

Data	Notation
Data register DT	"D"
Link data register LD	"L"
File register FL	"F"

Error response (Preset error)

% or <	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 16^1$ $\times 16^0$	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	---	---	------------------------------------	----------------

1.3 List of MEWTOCOL-COM Commands


1.3.18 [RT] Read the status of PLC

This reads information such as error codes if an error occurs in the programmable controller specifications.

Command

% or <	Destination $\times 10^1$ $\times 10^0$	#	R	T	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	--	---	---	---	------------------------------------	----------------

Normal response (Read successful)



Error response (Read error)

% or <	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 16^1$ $\times 16^0$	BCC $\times 16^1$ $\times 16^0$	C _R
--------------	---------------------------------------	---	---	------------------------------------	----------------

Model code

This expresses the CPU unit type as a 2-character decimal value.

Code	Model
20	FP2 and FP2SH

Version

This expresses the CPU version as a 2-character decimal value.

For example: 15 → Ver. 1.5

Program capacity

This expresses the program capacity by specified by system register no.0 as a 2-character decimal value. The value is expressed in k-step units.


Code	Program capacity	Last step address
02	2k steps	1534
n		1,024 x n - 512 - 2 For example: If n = 8, the value is 7,678.
16	16k steps	15870
32	32k steps	32254

(Note 1) With the FP2SH, this will be "0".

Operation mode

- The contents of special internal relays R9020 to R9027 are expressed as 2-character hexadecimal values.
- The user can check the settings of the mode selector switches on the CPU unit (RUN/ PROG./REMOTE), whether normal operation or test operation is being used, and other elements.


They are read using binary notation, as shown below.



Error flag

The statuses of the eight error flags (special internal relays) R9000 to R9007 are expressed as 2-character hexadecimal values.

They are read using binary notation, as shown below.



1.3 List of MEWTOCOL-COM Commands


Self-diagnostic error code

- If an error occurs, the self-diagnosis error code is expressed as a 4-digit hexadecimal value. Please be careful, since self-diagnosis error codes are normally treated as decimal values.
For example, if the content is read as "2D00" in hexadecimal format, the self-diagnosis error code will be "2D". In decimal notation it will be read as "45" (Operation error).
- If no error has occurred, the value will be "0000".


1.3.19 [RR] Read system register

This reads the contents of the system registers.


Command



Normal response (Read successful)



Error response (Read error)




1.3.20 [WR] Write system register

This sets the system registers.

1.3 List of MEWTOCOL-COM Commands

Command



Normal response (Write successful)

%	or	<	Source $\times 10^1$ $\times 10^0$	\$	W	R	BCC $\times 16^1$ $\times 16^0$	C _R
---	----	---	---------------------------------------	----	---	---	------------------------------------	----------------

Error response (Write error)

%	or	<	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 16^1$ $\times 16^0$	BCC $\times 16^1$ $\times 16^0$	C _R
---	----	---	---------------------------------------	---	---	------------------------------------	----------------

1.3.21 [RM] Remote control

This switches the operation mode of the programmable controller. It is effective only when the operation mode of the programmable controller is the REMOTE mode.

Command

%	or	<	Destination $\times 10^1$ $\times 10^0$	#	R	M	Operation code 1 character	BCC $\times 16^1$ $\times 16^0$	C _R
---	----	---	--	---	---	---	-------------------------------	------------------------------------	----------------

Normal response (Remote control successful)

%	or	<	Source $\times 10^1$ $\times 10^0$	\$	R	M	BCC $\times 16^1$ $\times 16^0$	C _R
---	----	---	---------------------------------------	----	---	---	------------------------------------	----------------

Operation code

Code	Operation
"R"	PROGRAM mode → RUN mode (booting)
"P"	RUN mode → PROGRAM mode (stopped)

Error response (Remote control error)

%	or	<	Source $\times 10^1$ $\times 10^0$	!	Error code $\times 16^1$ $\times 16^0$	BCC $\times 16^1$ $\times 16^0$	C _R
---	----	---	---------------------------------------	---	---	------------------------------------	----------------

1.3 List of MEWTOCOL-COM Commands

1.3.22 [AB] Abort

If a transmission is aborted while a multiple-frame response is being received from the programmable controller, this is issued from the side sending the command (the computer side).

Command

% or <	Destination $\times 10^1$, $\times 10^0$	#	A	B	BCC $\times 16^1$, $\times 16^0$	CR
--------------	--	---	---	---	--	----

Response


No response

2 MEWTOCOL-DAT (Data Transfer)

2.1 Overview of MEWTOCOL-DAT	2-2
2.2 List of MEWTOCOL-DAT Commands	2-4
2.2.1 [50H] Write data area	2-4
2.2.2 [51H] Read data area	2-5
2.2.3 [52H] Write contact information	2-6
2.2.4 [53H] Read contact information	2-6

2.1 Overview of MEWTOCOL-DAT

■ Overview of command and response



- (Note 1)
- A dedicated procedure and conversational-style format are used.
 - Data is sent as binary codes.
 - Transmission rights are transferred each time a command message is sent.
 - The maximum length for text data is 1020 words.
 - If the transmission source is a programmable controller, command messages are transmitted by executing the SEND and RECV commands.


Note

- With MEWTOCOL communication carried out through an ET-LAN unit, format is used in which the special header shown below is added to MEWTOCOL-DAT commands and responses.

Special header for ET-LAN unit	MEWTOCOL command/response
--------------------------------	---------------------------

- The content of the special header changes depending on the communication conditions.

■ Command code and Response code



■ Table of commands

Command code	Description	Corresponding response code
50H	Writing to a data area	D0H
51H	Reading from a data area	D1H
52H	Writing of contact information	D2H
53H	Reading of contact information	D3H

Note

- The corresponding response code is a value that is the reverse of the first bit (0 → 1) of the command code (1-byte binary code).
- The end code for a normal response is FFH, while that when an error occurs is an error code.

Info.

- Reference: "[3 MEWTOCOL Error Codes](#)"


2.2 List of MEWTOCOL-DAT Commands

2.2 List of MEWTOCOL-DAT Commands

2.2.1 [50H] Write data area

The specified number of words of data are written, starting from the specified first word number of the data area.

Command



Normal response (Write successful)

80H	D0H	FFH
-----	-----	-----

Error response (Write error)

80H	D0H	Error code
-----	-----	------------

Area code

Area type	Area code
Link relay (WL)	00
Internal relay (WR)	01
External output relay (WY)	02
External input relay (WX)	03
Timer/counter set value area (SV)	04
Timer/counter elapsed value area (EV)	05
Link data register (LD)	06
Special internal relay (WR)	07
Special data register (DT)	08
Data register (DT)	09

2.2 List of MEWTOCOL-DAT Commands

Area type	Area code
File register (FL)	0A

2.2.2 [51H] Read data area

The specified number of words of data are read, starting from the specified first word number of the data area.

Command

80H	51H	Area code	Starting word No.	No. of specified words n
			$\times 16^1$ $\times 16^0$ $\times 16^3$ $\times 16^2$	$\times 16^1$ $\times 16^0$ $\times 16^3$ $\times 16^2$
			(lower word) (higher word)	(lower word) (higher word)

Normal response (Read successful)

80H	D1H	FFH	Data contents ①	Data contents ②
			$\times 16^1$ $\times 16^0$ $\times 16^3$ $\times 16^2$	$\times 16^1$ $\times 16^0$ $\times 16^3$ $\times 16^2$
			(lower word) (higher word)	(lower word) (higher word)

Reading data n items

(For communication with the ET-LAN or MEWNET-H/MEWNET-W2 network: n = 1 to 1020)
 (For communication with the MEWNET-P/MEWNET-W network: n = 1 to 16)

Error response (Read error)

80H	D1H	Error code
-----	-----	------------

Area code


Area type	Area code
Link relay (WL)	00
Internal relay (WR)	01
External output relay (WY)	02
External input relay (WX)	03
Timer/counter set value area (SV)	04
Timer/counter elapsed value area (EV)	05
Link data register (LD)	06
Special internal relay (WR)	07
Special data register (DT)	08
Data register (DT)	09
File register (FL)	0A

2.2 List of MEWTOCOL-DAT Commands

2.2.3 [52H] Write contact information

Writing is carried out to the specified contact of the contact area.

Command



Normal response (Write successful)

80H	D2H	FFH
-----	-----	-----

Error response (Write error)

80H	D2H	Error code
-----	-----	------------

Area code


Area type	Area code
Link relay (WL)	00
Internal relay (WR)	01
External output relay (WY)	02
External input relay (WX)	03
Timer/counter set value area (SV)	04
Timer/counter elapsed value area (EV)	05
Link data register (LD)	06
Special internal relay (WR)	07
Special data register (DT)	08
Data register (DT)	09
File register (FL)	0A

2.2.4 [53H] Read contact information


Reading is carried out from the specified contact of the contact area.

2.2 List of MEWTOCOL-DAT Commands


Command



Normal response (Read successful)



Error response (Read error)



Area code

Area type	Area code
Link relay (WL)	00
Internal relay (WR)	01
External output relay (WY)	02
External input relay (WX)	03
Timer/counter set value area (SV)	04
Timer/counter elapsed value area (EV)	05
Link data register (LD)	06
Special internal relay (WR)	07
Special data register (DT)	08
Data register (DT)	09
File register (FL)	0A

(MEMO)

3 MEWTOCOL Error Codes

3.1 Table of Error Codes3-2

3.1 Table of Error Codes

3.1 Table of Error Codes

The same error codes are used for the computer link function and data link function.

■ Link system error

Error code	Error name	Steps to take
22H	WACK error	The receive buffer of the partner node has overflowed. Steps to take: Keep the data size within the maximum range.
23H	MEWTOCOL station No. overlap	The transmission has been interrupted because the MEWTOCOL station number of the source node duplicates that of another node. Steps to take: Change the setting for the MEWTOCOL station number and try again.
24H	ET-LAN unit hardware error	Hardware error in communication control unit Steps to take: Turn the power supply off and then on again. • If the error still occurs, replace the unit. • If the error does not occur, the malfunction may have been caused by noise. Check the installation and layout of the transmission line and the usage environment.
26H	MEWTOCOL station No. setting error	A value other than 01 to 64 and EE has been specified for the MEWTOCOL station number of the source node. Steps to take: Specify a MEWTOCOL station number within a range of 01 to 64 and EE.
27H	No support error	An attempt was made to send a packet that is not supported by the system. Steps to take: Please contact your dealer.
28H	No response error	Timeout error while waiting for response from partner station. Steps to take: Use the application program to send the transmission again.
30H	Time-out error	Ongoing transmission disabled status Steps to take: Use the application program to send the transmission again.
32H	Transmission impossible error	The transmission was interrupted because the buffer of the source node overflowed. Steps to take: Keep the data size within the maximum range.
33H	Communication stop	The transmission was interrupted because the network access switch of the MEWNET-H link unit serving as a relay was off. Steps to take: Turn on the network access switch.
36H	No destination error	• No partner station exists on the network. • Network access was disengaged. Steps to take: • Check to see if a partner station exists on the network. • Use the application program to send the transmission again.

Error code	Error name	Steps to take
38H	Other communication errors	Transmission error other than the above Steps to take: Use the application program to send the transmission again.

(Note 1) When the error occurred on the second or a higher hierarchy level of a multiple-hierarchy link, no response will be returned.

(Note 2) For basic procedure errors, processing errors, and programmable controller application errors, if a link-related error (including hierarchical) occurred within the network, no response will be returned.

■ Basic procedure error

Error code	Error name	Steps to take
40H	BCC error	When using the computer link function: A BCC error occurred in the command data. Steps to take: Use the application program to send the transmission again.
41H	Format error	<When using the computer link function> A command message was sent that does not fit the transmission format. • There is too much or too little command data. • “#” or “transmission destination” does not exist, or a similar problem For data transfer function An attempt was made to send a greater volume of data than can be transmitted. Steps to take: Correct the format and command.
42H	No support error	When using the computer link function: A command was sent that is not supported. A command is being sent to a destination that is not supported, etc. Steps to take: Use a command that is supported.
43H	Procedure error	When using the computer link function: While the programmable controller was waiting for a transmission request message (there was still more data to be sent), a different command was sent. Steps to take: Send the transmission request message to the partner node.

■ Processing error

Error code	Error name	Steps to take
50H	Link setting error	When using the computer link function: A route number has been specified that does not exist. Steps to take: Specify the route number correctly.
51H	Simultaneous operation error	When using the computer link function: When sending a command to another node, the transmission buffer of the sending machine overflowed. Steps to take:

3.1 Table of Error Codes

Error code	Error name	Steps to take
		Use the application program to send the transmission again.
52H	Transmit disable error	<When using the computer link function> Data cannot be transmitted to another node. Steps to take: Turn the power supply off and then on again. • If the error still occurs, replace the unit. • If the error does not occur, the malfunction may have been caused by noise. Check the installation and layout of the transmission line and the usage environment.
53H	Busy error	When using the computer link function: A command was received while multiple frames were being processed. Steps to take: Use the application program to send the transmission again.

■ PC application error

Error code	Error name	Steps to take
60H	Parameter error	When using the computer link function: The code used is for an area specification parameter that does not exist, or is a code that cannot be used with that command (X, Y, D, etc.). An inappropriate code is being used for the function specification parameter (0, 1, 2, etc.). Steps to take: Specify using the correct format code.
61H	Data error	When using the computer link function: An error occurred indicating that the specification for the contact number, area number, or the code format used to handle the data (BCD, HEX, etc.) is excessive, insufficient, or the wrong range has been specified. When using the data transfer function: The wrong field has been specified for the source node or another node. Steps to take: Specify using the correct format code.
62H	Registration error	When using the computer link function: Too many registrations have been entered, or a registration has not been entered (monitor registration, trace registration, etc.). When there are too many registrations, reset the registrations. Steps to take: Specify using the correct format code.
63H	Mode error	When using the computer link function: When a command was transmitted, the operation mode was one in which that command cannot be processed. Steps to take: Specify using the correct format code.
65H	Protect error	When using the computer link function: An attempt was made to write data to a program area or system register while the memory protect status was in effect. Steps to take: Data cannot be written while the memory protect status is in effect.

3.1 Table of Error Codes

Error code	Error name	Steps to take
66H	Address error	When using the computer link function: An error occurred indicating that the code format (BCD, HEX, etc.) for the address (program address, absolute address, etc.) data is excessive, insufficient, or the wrong range has been specified. Steps to take: Specify using the correct format code.
67H	No data error	When using the computer link function: The data to be read does not exist. (An attempt was made to read a comment registration or other data that has not been written.) Steps to take: Specify using the correct format code.
72H	Time-out error	When using the computer link function: Timeout error occurred while waiting for a transmission answer Steps to take: Use the application program to send the transmission again.
73H	Time-out error	When using the computer link function: Timeout error occurred while waiting for the transmission buffer to become empty Steps to take: Use the application program to send the transmission again.
74H	Time-out error	When using the computer link function: Timeout error occurred while waiting for a response Steps to take: Use the application program to send the transmission again.

(MEMO)

Revision History

The manual code is shown at the bottom of the cover page.

Date of issue	Manual code	Revision details
April 2022	WUME-MEWCP-01	First edition
November 2022	WUME-MEWCP-02	2nd edition Added information about the MEWTOCOL-COM command and 1:1 communication.
April 2024	WUME-MEWCP-03	3rd Edition Change in Corporate name

(MEMO)

(MEMO)

Panasonic Industry Co., Ltd.

1006, Oaza Kadoma, Kadoma-shi, Osaka 571-8506, Japan
<https://industry.panasonic.com/>

Please visit our website for inquiries and about our sales network.

© Panasonic Industry Co., Ltd. 2022-2024
April, 2024

WUME-MEWCP-03